## SIEMENS

## Data sheet

## 6ES7155-5AA00-0AC0



SIMATIC ET 200MP. PROFINET IO device Interface module IM 155-5 PN HF, for ET 200MP electronic modules; Up to 12 IO modules without PS; Up to 30 IO modules with additional PS; Integrated 2-port switch; RJ45 shared device; MRP; IRT >=0.25 ms; Isochronous mode FW update; I&M0...3; Prioritized startup, S2 redundancy; Shared device with 4 controllers Suitable for operation with active backplane bus (FW V4.4 or higher)

General information	
Product type designation	IM 155-5 PN HF
HW functional status	From FS03
Firmware version	V4.4
FW update possible	Yes
Device identifier (DeviceID)	0X0312
Product function	
<ul> <li>I&amp;M data</li> </ul>	Yes; I&M0 to I&M3
<ul> <li>Module swapping during operation (hot swapping)</li> </ul>	Yes
Isochronous mode	Yes
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	V16 with HSP 308
<ul> <li>STEP 7 configurable/integrated from version</li> </ul>	V5.5 SP3 / -
<ul> <li>PROFINET from GSD version/GSD revision</li> </ul>	V2.3 / -
Configuration control	
via user data	No
via dataset	Yes
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Short-circuit protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Input current	
Current consumption (rated value)	0.2 A
Current consumption, max.	1.2 A
Inrush current, max.	9 A
l²t	0.09 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	14 W
Power available from the backplane bus	2.3 W
Power loss	
Power loss, typ.	4.5 W
Address area	

Address space per medule	
Address space per module	256 byte: per input / output
Address space per module, max.     Address space per station	256 byte; per input / output
Address space per station, max.	512 byte; per input / output
Hardware configuration	
	Ver
Integrated power supply	Yes
System power supply can be plugged in to left of IM	Yes; only with design with U-connectors 3
Number of permissible power segments Rack	3
Modules per rack, max.	30; I/O modules
Submodules	30, 1/O modules
Number of submodules per station, max.	256
Interfaces	200
Number of PROFINET interfaces	1
	1
1. Interface	
Interface types	Vec
RJ 45 (Ethernet)	Yes 2
Number of ports	
integrated switch Protocols	Yes
PROFINET IO Device	Yes
Open IE communication	Yes
Media redundancy	Yes
Interface types	165
RJ 45 (Ethernet)	
Transmission procedure	PROFINET with 100 Mbit/s full duplex (100BASE-TX) Yes
<ul><li>100 Mbps</li><li>Autonegotiation</li></ul>	Yes
Autoregoliaion     Autoregoliaion	Yes
	163
Protocole	
Protocols	
PROFINET IO Device	
PROFINET IO Device Services	Ves
PROFINET IO Device Services — IRT	Yes
PROFINET IO Device Services — IRT — PROFlenergy	No
PROFINET IO Device Services — IRT — PROFlenergy — Prioritized startup	No Yes
PROFINET IO Device Services — IRT — PROFlenergy — Prioritized startup — Shared device	No Yes Yes
PROFINET IO Device Services — IRT — PROFlenergy — Prioritized startup	No Yes
PROFINET IO Device Services — IRT — PROFlenergy — Prioritized startup — Shared device — Number of IO Controllers with shared device,	No Yes Yes
PROFINET IO Device Services — IRT — PROFlenergy — Prioritized startup — Shared device — Number of IO Controllers with shared device, max.	No Yes Yes
PROFINET IO Device Services — IRT — PROFlenergy — Prioritized startup — Shared device — Number of IO Controllers with shared device, max. Redundancy mode	No Yes 4
PROFINET IO Device         Services         — IRT         — PROFlenergy         — Prioritized startup         — Shared device         — Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)	No Yes 4 Yes
PROFINET IO Device         Services         — IRT         — PROFlenergy         — Prioritized startup         — Shared device         — Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         — on S7-1500R/H	No Yes 4 Yes Yes
PROFINET IO Device         Services         — IRT         — PROFlenergy         — Prioritized startup         — Shared device         — Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         — on S7-1500R/H         — on S7-400H	No Yes 4 Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3
PROFINET IO Device         Services         — IRT         — PROFlenergy         — Prioritized startup         — Shared device         — Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         — on S7-1500R/H         — on S7-400H         • Redundant PROFINET configuration (R1)	No Yes Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No
PROFINET IO Device         Services         — IRT         — PROFlenergy         — Prioritized startup         — Shared device         — Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         — on S7-1500R/H         — on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding	No Yes Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No
PROFINET IO Device         Services         — IRT         — PROFlenergy         — Prioritized startup         — Shared device         — Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         — on S7-1500R/H         — on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy	No Yes 4 Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes
PROFINET IO Device         Services         — IRT         — PROFlenergy         — Prioritized startup         — Shared device         — Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         — on S7-1500R/H         — on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         — MRP         — MRPD         Open IE communication	No Yes Yes 4 Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP	No Yes 4 Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP	No Yes Yes 4 Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRP         SNMP         • LLDP	No Yes 4 Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP	No Yes Yes 4 Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP         • LLDP         Isochronous mode	No Yes Yes 4 Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP         • LLDP	No Yes Yes 4 Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP         • LLDP         Isochronous mode         Equidistance         shortest clock pulse         max. cycle	No Yes Yes 4 Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP         • LLDP         Isochronous mode	No Yes Yes 4 Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes Yes Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP         • LLDP         Isochronous mode         Equidistance         shortest clock pulse         max. cycle	No Yes Yes 4 Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes Yes Yes Yes Yes
PROFINET IO Device         Services         - IRT         - PROFlenergy         - Prioritized startup         - Shared device         - Number of IO Controllers with shared device, max.         Redundancy mode         • PROFINET system redundancy (S2)         - on S7-1500R/H         - on S7-400H         • Redundant PROFINET configuration (R1)         • H-Sync forwarding         Media redundancy         - MRP         - MRP         - MRPD         Open IE communication         • TCP/IP         • SNMP         • LLDP         Isochronous mode         Equidistance         shortest clock pulse         max. cycle	No Yes Yes 4 Yes Yes Yes; With GSDML file as of STEP 7 V5.5 SP3 No Yes Yes Yes Yes Yes Yes Yes

Diagnostics function	Yes
Diagnostics indication LED	
RUN LED	Yes; green LED
ERROR LED	Yes; red LED
MAINT LED	Yes; Yellow LED
<ul> <li>Connection display LINK TX/RX</li> </ul>	Yes; 2x green-yellow LEDs
Potential separation	
between backplane bus and electronics	No
between PROFINET and all other circuits	Yes
between supply and all other circuits	No
Isolation	
Isolation tested with	707 V DC (type test)
Ambient conditions	
Ambient temperature during operation	
<ul> <li>horizontal installation, min.</li> </ul>	-25 °C; from FS04
<ul> <li>horizontal installation, max.</li> </ul>	60 °C
<ul> <li>vertical installation, min.</li> </ul>	-25 °C; from FS04
<ul> <li>vertical installation, max.</li> </ul>	40 °C
Altitude during operation relating to sea level	
<ul> <li>Installation altitude above sea level, max.</li> </ul>	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
Connection method	
ET-Connection	
● via BU/BA Send	No
Dimensions	
Width	35 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	350 g
last modified:	1/18/2021 🖸